

	McNair		
	Concentration (ug/L)	Reporting Limit (ug/L)	Location
1st	6.27	2	DF/2nd Floor/NE Corner
2nd	<2	2	
1st	5.68	2	DF2nd Floor/NE Corner
2nd	<2	2	
1st	6.14	2	DF/2nd Floor/N Corridor
2nd	<2	2	
1st	9.86	2	DF/2nd Floor/N Corridor
2nd	<2	2	
1st	5.12	2	DF/1st Floor/NE Corner
2nd	<2	2	
1st	4.95	2	DF/1st Floor/NE Corner
2nd	<2	2	
1st	6.12	2	DF/1st Floor/ N Corridor
2nd	<2	2	
1st	6.49	2	DF/1st Floor/N Corridor
2nd	<2	2	
1st	6.44	2	DF/Gym
2nd	2.71	2	
1st	16.98	2	Sink/Room 1 - Board Room
2nd	2.81	2	
1st	6.48	2	Sink/Lounge-West
2nd	<2	2	
1st	<2	2	Sink/Lounge - East
2nd	<2	2	
1st	5.02	2	Sink/Art Room 13 East
2nd	<2	2	
1st	24.28	2	Sink/Room 14 Reesor
2nd	2.48	2	
1st	15.34	2	Sink/Room 25 Schaller
2nd	<2	2	
1st	14.84	2	Sink/Room 25 Schaller
2nd	<2	2	
1st	2.74	2	Kitchen Sink
2nd	<2	2	
1st	2.86	2	Kitchen Sink
2nd	6.31	2	
1st	<2	2	Kitchen Sink
2nd	5.44	2	
	S = SINK		